

## Sewage Pump Station Inspection Checklist

STATION LOCATION:

DATE (MM/DD/YY):

TIME STARTED (24:00):

TIME COMPLETED (24:00):

SERVICE FREQUENCY:

ITEM	INSPECTION REQUIRED	EQUIPMENT CONDITION	COMMENTS
<b>WET WELL</b>			
Grease Build-Up			
Floats			
Seal Flange			
Wench & Mounting Stand			
Electrical Cables			
Guide Rail System			
Sludge Build-Up			
Floating Debris			
<b>PUMPS</b>			
Operation			
Impeller			
Cable Connections			
<b>PUMP CONTROLS</b>			
H.O.A. Switches			
Moisture Sensors			
Starter Contacts			
Alternator Contacts			
Circuit Breakers			
<b>HIGH WATER ALARM PANEL</b>			
Operation			
<b>AUTO DIALER</b>			
Test in Remote			
Test on Line (Notify dispatcher)			
<b>ELECTRICAL</b>			
Breaker Panel			
Main Disconnects			
Lights			
Lock-out Switches			
Transfer Switches			
<b>FLOWMETER</b>			
Totalizer			
Chart Recorder			
Change Chart			
Check Pen			
<b>GENERATOR</b>			
Cycle Operation			
Coolant Svstem			
Coolant Change			
Check Oil			
Chanoe Oil w/filter			
Air Filter Replacement			
Exhaust System			
Engine Heater			
Tune-Up			
<b>L.P GAS SYSTEM</b>			
Fuel Level			
Valves & Regulator			
<b>VALVE VAULT</b>			
Air Relief Valve			
Plug Valves			
Check Valves			
Sumo Pump			
<b>BUILDING</b>			
Heater			
Ventilation System			
Plumbing			
Grounds & Housekeeping			